DWG. NO. ELN 2111 | SHEET NO. 7022



LEGEND

H1·4	1·4 Kg. HALON FIRE EXTINGUISHER
W9	9 Kg. WATER FIRE EXTINGUISHER
D4·5	4·5 Kg. DRY CHEMICAL FIRE EXTINGUISHER
D9	9 Kg. DRY CHEMICAL FIRE EXTINGUISHER
D68	68 Kg. DRY CHEMICAL FIRE EXTINGUISHER
C4·5	4·5 Kg. FIRE EXTINGUISHER CO_2
C9	9 Kg. FIRE EXTINGUISHER CO_2
C13·6	13·6 Kg. FIRE EXTINGUISHER CO_2
	FIRE WATER MONITOR
	WASHDOWN HOSE REEL
	FIRE WATER HOSE REEL
F	WATER/FOAM HOSE REEL
C	DRY CHEMICAL HOSE REEL
	BREAK GLASS UNIT - HALON MANUAL RELEASE
	MANUAL START STATION - WATER DELUGE (VESSEL NUMBER IN BRACKETS)
WFR	WATER/FOAM RELEASE LEVER FOR FIRE PUMP START
PR	POWER RELEASE LEVER
ESD	ESD BUTTON
FAB	FIRE ALARM BUTTON (ALARM & FIRE PUMP START)
FB	FIRE BLANKET
F	FIREMANS OUTFIT
BA	BREATHING APPARATUS
M	MUSTER ALARM
	EQUIPMENT COVERED WITH WATER DELUGE
	COMPARTMENTS COVERED WITH HALON
	ESCAPE ROUTES

AS BUILT
TO INFORMATION RECEIVED UP TO DEC 1977

NO.	BY	DATE	REVISIONS
1	CP	5 JULY 77	REVISED TO FIRE & SAFETY DRGS.
0	CP & GJ	MAY 77	NEW DRAWING

FAB. STDS. REQ'D. THIS SHT.

APPROVED:
McDERMOTT—HUDSON
DATE:
ENGINEERS APPROVAL — BY — DATE
PROJECT / STRUCTURAL / PROCESS / MECHANICAL / ELECTRICAL / INSTRUMENT / FAB. CHECK / PROP. CHECK

ELF - NORGE
FRIGG FIELD

QUARTERS PLATFORM
NORTH SEA — JOB 1-40-D2 — W.D.104M

McDERMOTT — HUDSON
LONDON — ENGLAND

DRAWN BY	SCALE	DATE	DWG NO.
CP / GJ	1 : 50	MAY 77	ELN 2111
DESIGNED BY			SHEET NO. 7022

FIRE CONTROL PLAN — LOWER FLOOR