DWG. NO.	SHEET NO.
ELN 2111	7025

50 MAN LIFEBOAT

(LIFEBOAT Nº 3)

PLATFORM NORTH

DOWN

UP

DOWN

FAB

LIFE JACKETS

RIG OFFICE

M6A

E1A

E1B

P12A

P12B

VDC 1

VDC 2

UP

DOWN

FAB

R7

H1.4

R1

UK TROPOSPHERIC EQUIPMENT ROOM

H1.4

R8

CONTROL ROOM

R12

AIR CONDITIONING ROOM

R2

35KVA ROTARY NO BREAK SYSTEM

R9

35KVA-ROTARY NO BREAK SYSTEM

R10

BATTERY ROOM

V6

R3

SWITCHGEAR ROOM

R4

BATTERY ROOM

UP

VDC 3

HATCH

STORAGE AREA

C4.5

H1.4

H1.4

C4.5

LIFE JACKETS

Q10

Q1

M6B

UP

FAB

HOSE RACK

DOWN

DOWN

LEGEND

- H1.4 — 1.4 Kg. HALON FIRE EXTINGUISHER
- W9 — 9 Kg. WATER FIRE EXTINGUISHER
- D4.5 — 4.5 Kg. DRY CHEMICAL FIRE EXTINGUISHER
- D9 — 9 Kg. DRY CHEMICAL FIRE EXTINGUISHER
- D68 — 68 Kg. DRY CHEMICAL FIRE EXTINGUISHER
- C4.5 — 4.5 Kg. FIRE EXTINGUISHER CO_2
- C9 — 9 Kg. FIRE EXTINGUISHER CO_2
- C13.6 — 13.6 Kg. FIRE EXTINGUISHER CO_2
- FIRE WATER MONITOR
- WASHDOWN HOSE REEL
- FIRE WATER HOSE REEL
- F — WATER/FOAM HOSE REEL
- C — DRY CHEMICAL HOSE REEL
- BREAK GLASS UNIT - HALON MANUAL RELEASE
- MANUAL START STATION - WATER DELUGE (VESSEL NUMBER IN BRACKETS)
- WFR — WATER/FOAM RELEASE LEVER FOR FIRE PUMP START
- PR — POWER RELEASE LEVER
- ESD — ESD BUTTON
- FAB — FIRE ALARM BUTTON (ALARM & FIRE PUMP START)
- FB — FIRE BLANKET
- F — FIREMANS OUTFIT
- BA — BREATHING APPARATUS
- M — MUSTER ALARM
- EQUIPMENT COVERED WITH WATER DELUGE
- COMPARTMENTS COVERED WITH HALON
- ESCAPE ROUTES

AS BUILT

TO INFORMATION RECEIVED UP TO DEC 1977

FAB. STDS. REQ'D. THIS SHT

DESIGN	ELEC.	INSTR.	PIPING	STRUCT	NO.	BY	DATE	REVISIONS	DATE	APP.

DESIGN	ELEC.	INSTR.	PIPING	STRUCT	NO.	BY	DATE	REVISIONS	DATE	APP.

DESIGN	ELEC.	INSTR.	PIPING	STRUCT	NO.	BY	DATE	REVISIONS	DATE	APP.
					0	GT	MAY 77	NEW DRAWING		

APPROVED :

DATE :

ENGINEERS APPROVAL

	BY	DATE
PROJECT		
STRUCTURAL		
PROCESS		
MECHANICAL		
ELECTRICAL		
INSTRUMENT		
FAB. CHECK		
PROD. CHECK		

ELF - NORGE

FRIGG FIELD

QUARTERS PLATFORM

NORTH SEA — JOB 1-40-D2 — W.D 104 M

McDERMOTT - HUDSON

LONDON — ENGLAND

DRAWN BY	SCALE	DATE	DWG. NO.
GMJ	1:50	30 MAY 77	ELN 2111
DESIGNED BY	CHECKED		SHEET NO. 7025

FIRE CONTROL PLAN - ROOF LEVEL

6

GAP 5606/75